



Figure similar

LOW-POWER PHASE CURRENT SENSOR CLOSED CORE TYPE ACCORDING TO IEC 61869-10 RATIO: 225 MV@700 A INNER DIAMETER 82 MM ACCURACY CLASS: 0.2 (FCM V 3.30 ONWARDS), ELSE 0.5 PROTECTION CLASS: 5P10 WITH CONNECTION CABLE 2.0 M OPEN END

Further information

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information- and Downloadcenter (catalogues, leaflets,...)

<https://www.siemens.com/energy-automation>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=6MD2320-0JA00-0BA1>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<https://support.industry.siemens.com/cs/ww/en/ps/6MD2320-0JA00-0BA1>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

https://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=6MD2320-0JA00-0BA1

Tender specifications

<https://www.siemens.com/specifications>

Power Academy - Your training and consulting partner in the area of power transmission and distribution

<https://www.siemens.com/poweracademy>

